

BY SEA		
SUBJECT: REFRIGERANT GAS R22 SAFISCEON		
TEST ITEMS	Specification	Analysis Results
INSPECTION STANDARD	GB/T 7373-2006	
APPEARANCE & ODOR	COLOURLESS, CLEAR, ODORLESS	
Purity , % by weight	$\geq 99.90$	99.98
Moisture , % by weight	$\leq 0.001$	0.0009
Acidity , (as in HCL), %	$\leq 0.00001$	0.00000
Evaporating Residue	$\leq 0.010$	0.0005
Chloride Cl-, %	PASS	PASS
Non-condensable Gas, %	$\leq 1.5$	0.95

This is to certify that we, the undersigned have inspected/ tested the quality of the mentioned goods, all goods have passed inspection satisfactory.